

Messung	Zählerstand Start	Zählerstand Ende	Menge m3	Dauer sec	kWh/Dauer	Leistung kW	Brennereinst.	Stillstandszeit min	Taußen	Modulationsgrad	Vorgang
1	3,8525	3,9935	0,141	210	1,199744636	20,57	modulierend		+5	automatisch	Heizung
2	4,1195	4,1875	0,068	135	0,57860025	15,43	Brenner 1-stufig		+5		Heizung
3	5,839	5,9284	0,0894	155	0,760689152	17,67	Brenner 1-stufig		+5		Heizung
4	7,1815	7,3295	0,148	240	1,259306427	18,89	Brenner 2-stufig		+5		Heizung
5	7,3295	7,4755	0,146	240	1,242288772	18,63	Brenner 2-stufig		+5		Heizung
6	7,8945	8,035	0,1405	230	1,195490223	18,71	Brenner 2-stufig		+5		Heizung
7	9,721	9,9015	0,1805	300	1,535843311	18,43	Brenner 1-stufig		+5		Heizung
8	9,9015	10,1425	0,241	355	2,050627357	20,80	Brenner 1-stufig		+5		Heizung
9	39,8525	39,9935	0,141	210	1,199744636	20,57	Brenner 1-stufig		+3		Heizung
10	41,4105	41,575	0,1645	265	1,399702076	19,01	Brenner 2-stufig	5	+3		Heizung
11	41,575	41,716	0,141	230	1,199744636	18,78	Brenner 2-stufig	5	+3		Heizung
12	48,855	49,019	0,164	205	1,395447662	24,51	Brenner 2-stufig	7	+3		Heizung
13	49,1505	49,306	0,1555	210	1,323122631	22,68	modulierend	5	+3	automatisch	Heizung
14	50,4605	50,6745	0,214	420	1,820889022	15,61	modulierend	7	5	35% manuell	WW-Bereitung
15	50,6745	50,855	0,1805	495	1,535843311	11,17	modulierend	16	5	35% manuell	Heizung
16	50,885	51,0455	0,1605	505	1,365666767	9,74	modulierend		5	30% manuell	Heizung