

Typ 200S ...E10 ohne Kühlung, ohne Warmwasser

WP_Aussentemperatur	viessmannapi.0.2225065.0.features.heating.sensors.temperature.outside.properties.value.value
WP_gemeinsame Vorlauftemperatur	viessmannapi.0.2225065.0.features.heating.boiler.sensors.temperature.commonSupply.properties.value.value
WP_Temperatur Pufferspeicher	viessmannapi.0.2225065.0.features.heating.buffer.sensors.temperature.main.properties.value.value
WP_Heizkörper_Umwälzpumpe	viessmannapi.0.2225065.0.features.heating.circuits.0.circulation.pump.properties.status.value
WP_Heizkörper_Umwälzpumpe_Frostschutz	viessmannapi.0.2225065.0.features.heating.circuits.0.frostprotection.properties.status.value
WP_Heizkörper_Niveau	viessmannapi.0.2225065.0.features.heating.circuits.0.heating.curve.properties.shift.value
WP_Heizkörper_Neigung	viessmannapi.0.2225065.0.features.heating.circuits.0.heating.curve.properties.slope.value
WP_Heizkörper_Zeitplan	viessmannapi.0.2225065.0.features.heating.circuits.0.heating.schedule.properties.entries.value
WP_Heizkörper_Komfort_Solltemperatur	viessmannapi.0.2225065.0.features.heating.circuits.0.operating.programs.comfortHeating.properties.temperature.value
WP_Heizkörper_Normal_Solltemperatur	viessmannapi.0.2225065.0.features.heating.circuits.0.operating.programs.normalHeating.properties.temperature.value
WP_Heizkörper_Reduziert_Solltemperatur	viessmannapi.0.2225065.0.features.heating.circuits.0.operating.programs.reducedHeating.properties.temperature.value
WP_Vorlauftemperatur Heizkörper	viessmannapi.0.2225065.0.features.heating.circuits.0.sensors.temperature.supply.properties.value.value
????	viessmannapi.0.2225065.0.features.heating.circuits.0.operating.programs.comfortEnergySaving.properties.reason.value
????	viessmannapi.0.2225065.0.features.heating.circuits.0.operating.programs.normalEnergySaving.properties.reason.value
WP_Heizkörper_FBH	viessmannapi.0.2225065.0.features.heating.circuits.1.circulation.pump.properties.status.value
WP_FBH_Umwälzpumpe_Frostschutz	viessmannapi.0.2225065.0.features.heating.circuits.1.frostprotection.properties.status.value
WP_FBH_Niveau	viessmannapi.0.2225065.0.features.heating.circuits.1.heating.curve.properties.shift.value
WP_FBH_Neigung	viessmannapi.0.2225065.0.features.heating.circuits.1.heating.curve.properties.slope.value
WP_FBH_Zeitplan	viessmannapi.0.2225065.0.features.heating.circuits.1.heating.schedule.properties.entries.value

WP_FBH_Komfort_Solltemperatur	viessmannapi.0.2225065.0.features.heating.circuits.1.operating.programs.comfortHeating.properties.temperature.value
WP_FBH_Normal_Solltemperatur	viessmannapi.0.2225065.0.features.heating.circuits.1.operating.programs.normalHeating.properties.temperature.value
WP_FBH_Reduziert_Solltemperatur	viessmannapi.0.2225065.0.features.heating.circuits.1.operating.programs.reducedHeating.properties.temperature.value
????	viessmannapi.0.2225065.0.features.heating.circuits.1.operating.programs.reducedEnergySaving.properties.reason.value
???	viessmannapi.0.2225065.0.features.heating.circuits.1.sensors.temperature.supply.properties.status.value
WP_FBH_Vorlauftemperatur	viessmannapi.0.2225065.0.features.heating.circuits.1.sensors.temperature.supply.properties.value.value
????	viessmannapi.0.2225065.0.features.heating.circuits.1.operating.programs.normalEnergySaving.properties.reason.value
WP_Stromverbrauch_HEUTE	viessmannapi.0.2225065.0.features.heating.power.consumption.summary.heating.properties.currentDay.value
WP_Stromverbrauch_MONAT	viessmannapi.0.2225065.0.features.heating.power.consumption.summary.heating.properties.currentMonth.value
WP_Stromverbrauch_JAHR	viessmannapi.0.2225065.0.features.heating.power.consumption.summary.heating.properties.currentYear.value
WP_Stromverbrauch_LETZTER_MONAT	viessmannapi.0.2225065.0.features.heating.power.consumption.summary.heating.properties.lastMonth.value
WP_Stromverbrauch_LETZTEN_7_TAGE	viessmannapi.0.2225065.0.features.heating.power.consumption.summary.heating.properties.lastSevenDays.value
WP_Stromverbrauch_LETZTES_JAHR	viessmannapi.0.2225065.0.features.heating.power.consumption.summary.heating.properties.lastYear.value
WP_Primärkreis_Temperatur	viessmannapi.0.2225065.0.features.heating.primaryCircuit.sensors.temperature.supply.properties.value.value
WP_Sekundärkreis_Temperatur	viessmannapi.0.2225065.0.features.heating.secondaryCircuit.sensors.temperature.supply.properties.value.value
????	viessmannapi.0.2225065.0.features.heating.sensors.temperature.return.properties.value.value
WP_Volumenstrom	viessmannapi.0.2225065.0.features.heating.sensors.volumetricFlow.allengra.properties.value.value
????	viessmannapi.0.2225065.0.features.heating.circuits.1.operating.programs.comfortEnergySaving.properties.reason.value
????	viessmannapi.0.2225065.0.features.heating.circuits.0.operating.programs.reducedEnergySaving.properties.reason.value